

SAFE DRINKING WATER CERTIFICATE

No.: _____

Date: 28/06/23.

It is certified that an inspection team headed by Dr. Rahul Gadpale,
Medical Officer from Primary Health Centre, Ankoli, Mandal Adilabad (Rural),
District Adilabad inspected the Aryabhata High School, Sy.No. 26/1, Mallapur
Village, Bheemsari Gram Panchayat, Adilabad (Rural) Mandal, Adilabad District
- 504001 on 28-06-2023 and found that the Aryabhata High School has safe
drinking water facilities for the students and members of staff of the institution as
per the norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of 28-06-2024.

Signature with Seal: _____


Name: _____

Designation: Medical Officer

Dr. Rahul Gadpale
28/06/23.
Medical Officer
PHC, ANKOLI
Dist. Adilabad

To
The Secretary/Correspondent
Aryabhata High School,
Sy.No. 26/1,
Mallapur Village,
Bheemsari Gram Panchayat,
Adilabad (Rural) Mandal,
Adilabad District - 504001


Principal
ARYABHATTA HIGH SCHOOL
MALLAPUR, ADILABAD.
Rc.No. B1/3774/2017
Dt: 01-12-2017


Correspondent
Aryabhata High School
ADILABAD

HEALTH AND SANITATION CERTIFICATE

No.: _____

Date: 28/06/2023

It is certified that an inspection team headed by Dr. Rahul Gadpale,
Medical Officer from Primary Health Centre, Ankoli, Mandal Adilabad (Rural),
District Adilabad inspected the Aryabhatta High School, Sy.No. 26/1, Mallapur
Village, Bheemsari Gram Panchayat, Adilabad (Rural) Mandal, Adilabad District
- 504001 on 28-06-2023 and found that the Aryabhatta High School is
maintaining the hygienic sanitation condition in the school building & the campus
as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of 28-06-2024.

Signature with Seal: _____

Name: Dr. Rahul Gadpale

Designation: Medical Officer

28/06/2023.
Medical Officer
PHC, ANKOLI
Dist: Adilabad

To
The Secretary/Correspondent
Aryabhatta High School,
Sy.No. 26/1,
Mallapur Village,
Bheemsari Gram Panchayat,
Adilabad (Rural) Mandal,
Adilabad District - 504001


Principal
ARYABHATTA HIGH SCHOOL
MALLAPUR, ADILABAD.
Rc.No. B1/3774/2017
Dt: 01-12-2017


Correspondent
Aryabhatta High School
ADILABAD

GOVERNMENT OF TELANGANA
WATER QUALITY MONITORING LABORATORY MISSION BHAGIRATHA ADILABAD
REPORT ON CHEMICAL ANALYSIS OF DRINKING WATER

Name & Address of Sender : Aryabhata High School Mandal : Adilabad
 Sample Collected by : Aryabhata High School Habitation : Mallapur

Date of Collected : 08.04.2024
 Date of Received : 10.04.2024

SI.No	Source	PH	Total Dissolved Solids	Alkalinity (Methyl Orange)	Total Hardness	Chloride	Fluoride	Nitrate as NO3	Calcium	Sulphate	Iron	Remarks
	Source	6.5 to 8.5	75-500 (Mg/Lt)	200 (Mg/Lt)	300 (Mg/Lt)	250 (Mg/Lt)	1 (Mg/Lt)	45 (Mg/Lt)	75 (Mg/Lt)	200 (Mg/Lt)	0.3 (Mg/Lt)	
	ACCEPTABLE LIMIT											
	PERMISSABLE LIMIT IN THE ABSENCE OF ALTERNATE SOURCE											
	Gramapanchayat											
	Mandal											
	Adilabad											
	Bheemsari											
	Mallapur											
	Aryabhata School											
	R.O	7.36	44	32	28	20	0.20	2	4	12	0.02	

Note: Standards as per Burea of Indian Standards I.S.10500:2012


 Asst Chemist
 MB Intra Adilabad
 ADILABAD

Asst Chemist
MB Intra Adilabad